



TC 10372

Telephone 0484-2623576
email -qcsdienkamaly@gmail.com

KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LAB, ANKAMALY
WATER TEST REPORT

ULR No.TC1037223000001495F

Report Issue Date:20.07.2023

Customer Name & Address			Date of Receipt of Payment	14.07.2023	
Dr.N. INTERNATIONAL SCHOOL, PARAVOOR			Date of Sample received	19.07.2023	
			Sample Given by	Customer	
			Sample Code	ANK/1541/07/2023	
			Sample Name	Drinking Water	
			Sample Condition	Good	
			Source of Sample	WELL	
			Sample Quantity	2 Litre	
			Test performing dates :20.07.2023		
Sl.No	Characteristics	Unit	Test Method	Acceptable Limit as per IS 10500-2012	Result
1	Turbidity	NTU	IS 3025 (Part10)-1984(Reaffirmed 2017)	1.0	0.3
2	pH at 25°C	-	IS 3025 (Part 11)2022	6.5 to 8.5	7.1
3	Total Hardness (as CaCO ₃)	mg/L	IS 3025 (Part21)-2009(Reaffirmed 2019)	200	8
4	Chloride (as Cl)	mg/L	IS 3025 (Part 32)-1988(Reaffirmed 2019)	250	5.8

Remarks:- BDL- BELOW DETECTION LIMIT, DL- DETECTION LIMIT

- NB:-1) The result stated above related only to the sample(s) submitted for testing by the customer.
2) The samples retain for 15 days from the end date of analysis
3) The test certificate shall not be reproduced except in full without the written approval of the Laboratory

Analysed By

Syama S.

Technical Manager

KWA/QCSDL/ANK/F 21

Rev.No:02

Rev.Date :12/07/2023

Issue Date : 02.07.2021

Page 1 of 1

End of Report

QUALITY MANAGER
QUALITY CONTROL SUB DISTRICT LAB
ANKAMALY

Authorized By

ANEESHA SEBASTIAN



For Dr. N. INTERNATIONAL SCHOOL

Principal

For Dr. N. INTERNATIONAL SCHOOL

Manager





Telephone 0484-2623576
email-qcsdlankamaly@gmail.co

KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LAB, ANKAMALY
WATER TEST REPORT

REPORT NO:ANK/QCSDL/1541/23-24

Report Issue Date:20.07.2023

Customer Name & Address		Date of Receipt of Payment		14.07.2023	
Dr.N. INTERNATIONAL SCHOOL, PARAVOOR		Date of Sample received		19.07.2023	
		Sample Given by		Customer	
		Sample Code		ANK/1541/07/2023	
		Sample Name		Drinking Water	
		Sample Condition		Good	
		Source of Sample		WELL	
		Sample Quantity		2 Litre	
		Test performing dates :20.07.2023		From:20.07.2023	
Sl.No	Characteristics	Unit	Test Method	Acceptable Limit as per IS 10500-2012	Result
1	Iron (as Fe)	mg/L	IS 3025(part 53) -2003(Reaffirmed 2019)	1	BDL(DL=0.1)
2	Nitrate (as NO3)	mg/L	APHA 4500-NO3- B 2012	45	6.8
3	Electrical Conductivity	micromhos/cm	IS 3025(part14)-2013(Reaffirmed 2019)	-	54.0

Analysed By

Syama S.

Technical Manager


End of Report

Authorized By

ANEESHA SEBASTIAN

KWA/QCSDL/ANK/F 21		Issue Date : 02.07.2021	
Rev No:02	Rev.Date :12.07.2023	Page 1 of 1	QUALITY MANAGER

QUALITY CONTROL SUB DISTRICT LAB
ANKAMALY



For Dr. N. INTERNATIONAL SCHOOL

Manager



For Dr. N. INTERNATIONAL SCHOOL

Principal



KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LAB, ANKAMALY
WATER ANALYSIS REPORT

REPORT NO: ANK/1541/23-24

Report Issue Date: 20.07.2023

3 Dr.N. INTERNATIONAL SCHOOL, PARAVOOR	Date of Receipt of Payment	14.07.2023	
	Date of Sample received	19.07.2023	
	Sample Given by	Customer	
	Sample Code	ANK/BC209/07/23	
	Sample Name	Drinking Water	
	Sample Condition	Good	
	Source of Sample	WELL	
	Sample Quantity	200ml	
	Test performing dates : 19.07.2023 From: 20.07.2023		
Sl. No.	Source	No of Coliforms per 100ml of sample	E.Coli in 100ml of sample
1	Water sample submitted by the customer	64CFU/100ML	ABSENT

Remarks:-

NB:-The result stated above related only to the sample(s) submitted for testing by the customer. The test certificate shall not be reproduced except in full without the written approval of the Laboratory

Authorized By

End of Report

KWA/QCSDL/ANK/01-2022	Issue Date : 01.06.2022
Rev No: Nil	Rev Date: Nil
	Page 1 of 1



For Dr. N. INTERNATIONAL SCHOOL

Manager

For Dr. N. INTERNATIONAL SCHOOL

Principal

